

FIRE SAFETY CERTIFICATE

UNDER APPENDIX XII OF CENTRAL BOARD OF SECONDARY EDUCATION CIRCULAR
NO.12/2022 DATED 14.10.2022

NO: 151 /2025

R.C.NO: 532 / V /2025


DATE: 16.06.2025

Certified that the **ST. JAMES ACADEMY** at **T.S.NO.4 PART, 20 PART, 21, 24PART, BLOCK-5&6, WARD- AC, (OLD WARD- L), NO. 49J, 28, BHARATHIYAR SALAI, TIRUCHIRAPPALLI- 620001, TAMILNADU, COMPRISED OF GROUND FLOOR , FIRST AND 2ND FLOOR** Owned by **ST. JAMES ACADEMY** have complied with the fire prevention and the fire safety requirements in accordance with rule of state Fire Service, and verified by **P.SATHIYAVARTHANAN,B.SC.,B.L., ASSISTANT DISTRICT OFFICER,** on **16.06.2025** in the presence of the **CORRESPONDENT, ST. JAMES ACADEMY** And that the proposed buildings are fit for occupancy in accordance with rule and subject to compliance of specific conditions as appended:-

CONDITIONS

- (i) AS PER NATIONAL BUILDING CODE 2016 ALL PASSIVE MEASURES SHOULD BE FOLLOWED.
- (ii) NO CHANGES SHOULD BE MADE TO THE SETTINGS IN THE APPROVED PLAN.
- (iii) AS PER NATIONAL BUILDING CODE 2016 ALL FIRE FIGHTING EQUIPMENTS SHOULD BE INSTALLED AND MAINTAIN PROPERLY. SHOULD BE DESIGNATE A PERSON RESPONSIBLE FOR FIRE AND LIFE SAFETY. SHOULD BE CONDUCT BASIC FIRE FIGHTING AND EVACUATION DRILL AND FIRE MOCK DRILL ONCE IN THREE MONTHS.




Signature with Seal

Name: **P. SATHIYAVARTHANAN, B.SC., B.L.,**

Designation: **ASSISTANT DISTRICT OFFICER,**

Name & Address of Department/Office: **TAMIL NADU FIRE AND RESCUE SERVICE,
TIRUCHIRAPPALLI STATION.**

TO:

**THE CORRESPONDENT,
ST. JAMES ACADEMY,
NO. 49J, 28, BHARATHIYAR SALAI,
TIRUCHIRAPPALLI- 620001, TAMILNADU.**

**COPY TO: DISTRICT OFFICER, TAMIL NADU FIRE AND RESCUE SERVICE,
TIRUCHIRAPPALLI DISTRICT.**

ENDORSEMENT

THE NO OBJECTION CERTIFICATE ISSUED BY FIRE SERVICE STAND CANCELLED AND ANNULLED DUE
TO.....

.....(REASONS TO BE RECORDED)

(NAME AND DESIGNATION OF THE AUTHORISED SIGNATORY)